



Training Object address:

- CPH / RFF training site in the South.

Training Object Capabilities/Limitations:

- **Engine Mockup:** Simulated attack on engine using handheld hose
- **Cross Tank:** Simulated extinguishing of liquid fire

Important restrictions

- Objects must **not** be extinguished using foam tender cannon
- Objects must **not** be used in basic fire training unless a special agreement/safety assessment has been conducted
- **Cross Tank:** Be very aware that the water level must not become too high due to potential overflow and ignition of spilled liquid
- Cross Tank is filled halfway with water, then a small amount of **JET-FUEL** from tank, and a small amount of **GASOLINE** from drum is added. Ignition must be done with caution
- **Engine Fire:** The container under the installation is filled with water to reduce heat to the unit

Marking Options:

- Objects are not to be combined with other scenarios than the intended extinguishing scenarioSmoke machine

Emergency Exits/Escape Routes:

- Objects are placed outdoors with good retreat distance

Safety Team:

- Instructor maintains contact and supervision of participating trainees and is ready to clearly interrupt the exercise in case of unintended incident
- In addition to the team performing extinguishing, a backup team of trainees is ready to perform safety/extinguishing using an extra deployed hose

Protective Equipment:

- During the exercise, participants must wear firefighting suit, helmet, gloves, and breathing apparatus/mask
- Instructor may, if positioned outside smoke exposure, stand without breathing apparatus. Instructor must always wear firefighting suit

Relevant Industry Guidelines Available Electronically at CARFA:

- "Personal Protective Equipment"
- "Safety and Health During Exercises"
- "Guidelines on Personal Safety in the Use of Fire Training Objects"

First Aid and Resuscitation Equipment:

- Located in the administration/changing pavilions, just inside the main entrance.

Accident and Alarm Procedures:

- Alarms are raised by the instructor via phone to OC at 32312000 or via SINE radio to OC.

Preparation / Review Before Using the Training Object:

- Designation of responsible instructor
- Identification of location of first aid equipment
- Alarm options
- Ensuring all participants use required protective equipment: helmet, gloves, firefighting suit, breathing apparatus

Reporting Safety Deficiencies in the Object:

- The responsible instructor is contacted and assesses whether the object is safe to use
- CARFA administrative personnel report the defect.

Reporting Injuries / Near-Miss Incidents:

- Procedure D4 "Reporting of Work Injuries" is followed for CPH employees
- Form "Internal Report of Work Accident" is completed for CPH employees
- Employees from other companies must report injuries to their own employer
- Immediate supervisors of those involved are informed
- Duty incident commander is informed
- Safety representative is informed
- In case of serious accident, AMI is contacted by phone
- In case of "Near-Miss Incident," the nearest supervisor is contacted to investigate the incident and prevent future occurrences